

FIRE TEST QUALIFICATION CERTIFICATE



Score (Europe) Ltd



Item	Ball Valve AF48 SER. ETO Valve
Size	1 1/2"
Class	600
Serial no	15-AF48-6666AI/ETo-B-0.8
Body material	ASTM A276 316L
Seat	TFM
Manufactured by	Habonim Industrial Valves Limited
In accordance with job number	138079
In accordance with drawing number	15-AF48-6666AI/ETo-B-0.8

The above valve was tested by **Score (Europe) Ltd** at their **Specialised Valve Research and Test Centre, Cowdenbeath, Scotland** and the results have been recorded as a **PASS**, having complied with the minimum performance requirements stated in **specification**

Test date	API 607 Fourth Edition, May 1993
Other sizes qualified	15 th April 2004
Other pressure ranges qualified	1 1/4", 1 1/2", 2", 2 1/2"
	600, 800, 900

Tested by W. Hay / S. Fox
S. Penman

Witnessed by W. Campbell - Lloyds Register EMEA



W. Campbell
- 7 MAY 2004

This certificate must be read in conjunction with the full **Score Test Report Number**

138079-2