



Industrie Service

# FIRE TEST QUALIFICATION CERTIFICATE

# Applus<sup>+</sup> RTD

NDT & Inspection


<b>Item</b>	Ball Valve
<b>Size</b>	2"
<b>Class</b>	400 lbs
<b>A<sup>+</sup> RTD ID No.</b>	A <sup>+</sup> 53551002
<b>Stem seal material</b>	PEEK and C.F. PTFE
<b>Body material</b>	CF8M
<b>Seat material</b>	Carbon filled PTFE
<b>Manufactured by</b>	Habonim
<b>In accordance with PO no.</b>	40147774
<b>In accordance with drawing no.</b>	20-AF47X-TEST-VALVE-SEC

The above valve was tested by Applus RTD Meettechniek at their valve testing facilities in Kapelle, the Netherlands. And the results have been recorded as PASS, having complied with the minimum performance requirements stated in specification:

ANSI/API Standard 607 6th Edition, September 2010  
&  
ISO 10497:2010, Testing of valves  
Fire type-testing requirements

<b>Test date</b>	5 <sup>th</sup> of October
<b>Other sizes qualified</b>	2 inch and below DN 50 and below
<b>Other pressure ranges qualified</b>	400 Lbs, 600 Lbs and 800 Lbs PN 100 and PN 150


Tested by:



F. Huiszoon (A<sup>+</sup> RTD)

Date: 05/10/2010

Witnessed by:



P. Deleu (TÜV SÜD)

Date: 05/10/2010

This certificate must be read in conjunction with the full Applus RTD Meettechniek test report number:

053551-R002